

Transformer Maintenance 2026

<i>Sub Station</i>	<i>Serial No</i>	<i>Work required</i>	<i>Date</i>	<i>Time</i>	<i>HRS</i>	<i>LV Maint</i>
Sub A - 1 ('STANLIB Com)	T 4842 / 2		21/01/2026	20H00-20H30	0.5	YES
Sub A - 2 (Virgin Active)	T 4842 / 4	Retape LT	21/01/2026	20H30-21H00	0.5	YES
Sub A - 2 (Virgin Active)	T 4842 / 4	Replace Silica gel	21/01/2026	20H30-21H00		
Sub A - 3 (Pie Centre)	T 5227 / 1	Replace Silica gel	21/01/2026	21H00-21H45	0.75	YES
Sub A - 4 (Bid Vest)	T 4842 / 3		21/01/2026	21H45-22H30	0.75	YES
Sub A - 5 (Ocean Basket)	T 4843 / 1	Retape HT<	21/01/2026	22H30-01H00	2.5	YES
Sub A - 5 (Ocean Basket)	T 4843 / 1	Repair top ,lid	21/01/2026	22H30-01H00		
Sub A - 5 (Ocean Basket)	T 4843 / 1	Retape busbar	21/01/2026	22H30-01H00		
Sub B - 1 (10 Melrose Blvd)	T 4844 / 5	Replace drain valve	22/01/2026	01H00-03H00	2	YES
Sub B - 1 (10 Melrose Blvd)	71941 / 01 / 001	Resample	22/01/2026	01H00-03H00		
Sub B - 1 (10 Melrose Blvd)	71941 / 01 / 001	Top up oil	22/01/2026	01H00-03H00		
Sub B - 2 ('STANLIB Building)	T4844 / 3	Replace drain valve	22/01/2026	20H00-22H00	2	YES
Sub B - 2 ('STANLIB Building)	T 4844 / 1		22/01/2026	20H00-22H00		
Sub B - 3 (Melrose No 3)	71231/02/001	Retape LT	22/01/2026	22H00-23H00	1	YES
Sub B - 3 (Melrose No 3)	71231/02/002	Retape LT	22/01/2026	22H00-23H00		
Sub B - 3 (Melrose No 3)	71231/02/002	Replace drain valve	22/01/2026	22H00-23H00		
Sub B - 3 (Melrose No 3)	71231/02/002	Repair top ,lid	22/01/2026	22H00-23H00		
Sub B - 3 (Melrose No 3)	71231/02/002	Resample	22/01/2026	22H00-23H00		
Sub B - 4 (Melrose No 1)	71231/01/002	Retape HT	22/01/2026	23H00-00H00	1	YES
Sub B - 4 (Melrose No 1)	71231/01/001	Retape HT	22/01/2026	23H00-00H00		
Sub C - 1 (African Pride Hotel)	T 4845 / 1	Top up oil	23/01/2026	00H00-01H00	1	YES
Sub C - 1 (African Pride Hotel)	T 5227 / 2	Retape HT	23/01/2026	00H00-01H00		
Sub C - 2 (Mezzanine Level 13)	T 4845 / 4	Purify 6 passes	23/01/2026	01H00-04H00	3	YES
Sub C - 2 (Mezzanine Level 13)	T 4845 / 3		23/01/2026	01H00-04H00		
Sub C - 2 (Mezzanine Level 13)	T 4845 / 2		23/01/2026	01H00-04H00		
Sub C - 3 (Building E 2)	T 4844 / 2	Repair top lid	23/01/2026	20H00-21H00	1	YES
Sub C - 3 (Building E 2)	T 4844 / 4		23/01/2026	20H00-21H00		

Sub No 2 (District Cooling) - 1	T 5751 / 1		23/01/2026	21H00-22H30	1.5	YES
Sub No 2 (District Cooling) - 2	05313 / 01 / 002	Retape LT	23/01/2026	22H30-00H30	2	YES
Sub No 2 (District Cooling) - 2	05313 / 01 / 002	Repair HT Bushing	23/01/2026	22H30-00H30		
Sub No 2 (District Cooling) - 2	05313 / 01 / 002	Resample	23/01/2026	22H30-00H30		
Sub No 2 (District Cooling) - 3	03803 / 01 / 02	Purify 4 passes	24/01/2026	00H30-02H30	2	YES
Sub No 2 (District Cooling) - 3	03803 / 01 / 02	Replace Silica gel	24/01/2026	00H30-02H30		
Sub No 2 (District Cooling) - 4	07263 / 01 / 001	Resample	24/01/2026	00H30-02H30		
Sub D - 1 (Sliding Gate) - 1	71942 / 02 / 001	Repair tap change	24/01/2026	02H30-06H30	4	YES
Sub D - 1 (Sliding Gate) - 2	71942 / 01 / 006	Resample	24/01/2026	02H30-06H30		
Sub D - 1 (Sliding Gate) - 3	71942 / 01 / 007	Repair tap handle	24/01/2026	02H30-06H30		
Sub D - 1 (Sliding Gate) - 3	71942 / 01 / 007	Resample	24/01/2026	02H30-06H30		
Sub E - 1 (Fire & Ice Hotel)	03803 / 01 / 01	Repair top lid	24/01/2026	20H00-21H00	1	YES
Sub E - 1 (Fire & Ice Hotel)	71941 / 02 / 001	Retorque top lid	24/01/2026	20H00-21H00		
Sub E - 2 (40 On Oak)	07230 / 01 / 001	Retape HT<	24/01/2026	21H00-22H00	1	YES
Sub E - 3 (The Piazza) - 1	71942 / 01 / 001	Resample	24/01/2026	22H00-02H00	4	YES
Sub E - 3 (The Piazza) - 2	71942 / 01 / 004	Lift top for inspection	24/01/2026	22H00-02H00		
Sub E - 3 (The Piazza) - 3	71942 / 01 / 003	Lift top for inspection	24/01/2026	22H00-02H00		
Sub E - 3 (The Piazza) - 3	71942 / 01 / 003	Retorque top lid	24/01/2026	22H00-02H00		
Sub E - 3 (The Piazza) - 3	71942 / 01 / 003	Clean TX	24/01/2026	22H00-02H00		
Sub E - 3 (The Piazza) - 4	71942 / 01 / 002		24/01/2026	22H00-02H00		
Sub E - 3 (The Piazza) - 5	71942 / 01 / 005		24/01/2026	22H00-02H00		
Bentley Sub	T 4842 / 1	Purify 4 passes	24/01/2026	08H00-10H00	2	NO
A5 Mini Sub	12531		25/01/2026	02H00-02H30	0.5	YES
One on whitely Residential	L 712/01/002	Repair Bucholtz	25/01/2026	02H30-03H00	0.5	YES
One on whitely Retail	L 7712/02/001	Repair Bucholtz	25/01/2026	03H00-03H30	0.5	YES
Marriott	L 7712/01/003	Repair top lid	25/01/2026	03H30-04H30	1	YES
Marriott	L 7712/01/003	Clean tx	25/01/2026	03H30-04H30		
Marriott	L 7712/01/001	Repair top lid	25/01/2026	03H30-04H30		
Marriott	L 7712/01/001	Clean tx	25/01/2026	03H30-04H30		
39 Melrose Blvd (Worley) Tx 1	13000000631001		25/01/2026	04H30-06H00	1.5	YES
39 Melrose Blvd (Worley) Tx 2	13000000630001		25/01/2026	04H30-06H00		

A3 Building Tx 1	61641/01/001					
Spare Transformers						
Fire & Ice Hotel	71941 / 01 / 002					